

Mark A. Franciosi
Technical Service Engineer
Building Envelope

July 29, 2009

USG Corporation
Dan Collins
Wallboard Product Manager
550 West Adams Street
Chicago, IL 60661-3676
312-436-5918

RE: United States Gypsum - Securock™

Dear Mr. Collins,

We have evaluated submitted samples of USG - Securock™ sheathing and have concluded the following:

Applications requiring the use of any of our sheet membranes (Perm-A-Barrier Wall Membrane, Perm-A-Barrier Detail Membrane or Perm-A-Barrier Wall Flashing), will require two applications of Perm-A-Barrier WB Primer.

Applications requiring the use of our fluid applied air barriers (Perm-A-Barrier Liquid and Perm-A-Barrier VP) can be installed per our standard application instructions.

Our data sheets and application installation instructions for can be found on our website at www.graceconstruction.com.

If you have any questions, please feel free to call me at the number listed above.

Sincerely,



Mark A. Franciosi
Technical Service Engineer
Building Envelope

cc: S. Santos – WR Grace