



RUBBER POLYMER CORPORATION

1135 WEST PORTAGE TRAIL EXT.
PHONE (330) 945-7721

AKRON, OH 44313-8283
TOLL FREE 1-800-860-7721 FAX (330) 9416

January 20, 2009

To: Dan Collins
USG Corporation

Re: Air Barrier membranes compatibility to Securock

We have successfully completed testing compatibility and adhesion of our Air Barrier products to the Securock Glass Mat Sheathing samples you provided. The products tested were as follows:

Rub-R-Wall Airtight Air/Vapor Barrier
Rub-R-Wall Airtight VP Vapor Permeable Air Barrier
Rub-R-Wall SA Primer

After applying the proper millage of each product and allowing them to completely cure, we observed no compatibility problems and the adhesion of each product to the sheathing was excellent. We will be adding your new sheathing to our approval list.

Regards,

David Ruggieri
RPC, Inc.