

FIRECODE® Brand Acrylic Firestop Spray Sealant Type SA

Application

Working pressure shall be minimum 2000 psi with a delivery rate of minimum 1.0 gpm. The spray tip orifice shall be 0.023". A larger tip may be used if the pump can support it. The fluid line is minimum 3/8" i.d. for a length of up to 50'. Equipment should be flushed with water at the end of the day. Airless spray equipment operates at extremely high pressures; protective clothing, gloves and eye protection are required.

Apply FIRECODE Brand Acrylic Firestop Spray Sealant (Type SA) to the required depth using spray equipment, brush or trowel. The application should extend 1/2" onto both the deck and wall surfaces to ensure proper installation of the sealant over the entire joint area. Masking tape can be utilized to create a neat appearance.

Trademarks

The following trademarks used herein are owned by United States Gypsum Company or a related company: FIRECODE.

Note

Products described here may not be available in all geographic markets. Consult your U.S. Gypsum Company sales office or representative for information.

Notice

We shall not be liable for incidental or consequential damages, directly or indirectly sustained, nor for any loss caused by application of these goods not in accordance with current printed instructions or for other than their intended use. Our liability is expressly limited to replacement of defective goods. Any claim shall be deemed waived unless made in writing to us within thirty (30) days from the date it was or reasonably should have been discovered.

SAFETY FIRST!

Follow good safety practices. Read material safety data sheets and related literature on products before specification and/or installation.

